## **Energy performance certificate (EPC)**

10 Maplehurst Close KINGSTON UPON THAMES KT1 2HD Energy rating

Valid until:

5 January 2032

Certificate number: 0099-0212-2502-1606-8504

Property type

Mid-floor flat

Total floor area

51 square metres

## Rules on letting this property


Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

# Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be B.

See how to improve this property's energy performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

# Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- · very good (most efficient)
- good
- average
- poor
- · very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Window	Fully double glazed	Average
Main heating	Room heaters, electric	Very poor
Main heating control	Appliance thermostats	Good
Hot water	Electric immersion, off-peak	Poor
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	(another dwelling below)	N/A
Secondary heating	Room heaters, electric	N/A

### Primary energy use

The primary energy use for this property per year is 208 kilowatt hours per square metre (kWh/m2).

perty produces	1.8 tonnes of CO2
perty's potential on	1.8 tonnes of CO2
By making the <u>recommended changes</u> , you could reduce this property's CO2 emissions by 0.0 tonnes per year. This will help to protect the environment.	
1-12	
use. They may not i	e occupancy and reflect how energy is
assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.	

## How to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from C (76) to B (82).

Recommendation Typical installation cost Typical yearly saving

1. High heat retention storage heaters

£1,200 - £1,800

£104

#### Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

# Estimated energy use and potential savings

Estimated yearly energy cost for this property	£466
Potential saving	£104

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in <u>how to improve this property's energy performance</u>.

For advice on how to reduce your energy bills visit <u>Simple Energy Advice</u> (<a href="https://www.simpleenergyadvice.org.uk/">https://www.simpleenergyadvice.org.uk/</a>).

#### Heating use in this property

Heating a property usually makes up the majority of energy costs.

#### Estimated energy used to heat this property

Space heating	1350 kWh per year
Water heating	1817 kWh per year

# Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive Renewable Heat Incentive payments (https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

### Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

#### Assessor contact details

Assessor's name Luke Nash Telephone 07598773947

Email <u>luke@apertours.co.uk</u>

#### Accreditation scheme contact details

Accreditation scheme Quidos Limited
Assessor ID QUID208205
Telephone 01225 667 570
Email info@guidos.co.uk

#### Assessment details

Assessor's declaration

Date of assessment

Date of certificate

6 January 2022

Date of Certificate

Company 2022

Type of assessment RdSAP