

# Energy performance certificate (EPC)

42, Lairgate BEVERLEY HU17 8EU	Energy rating <b>E</b>	Valid until: <b>15 September 2026</b>
		Certificate number: <b>9558-9098-7211-1356-3970</b>

## Property type

Mid-terrace house

## Total floor area

80 square metres

## Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be B.

[See how to improve this property's energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		84   B
69-80	C		
55-68	D		
39-54	E	42   E	
21-38	F		
1-20	G		

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Poor
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, no insulation (assumed)	Very poor

Feature	Description	Rating
Roof	Pitched, limited insulation	Very poor
Roof	Pitched, limited insulation (assumed)	Very poor
Window	Fully double glazed	Good
Main heating	Room heaters, mains gas	Average
Main heating control	No thermostatic control of room temperature	Poor
Hot water	Gas multipoint	Average
Lighting	No low energy lighting	Very poor
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Portable electric heaters (assumed)	N/A

## Primary energy use

The primary energy use for this property per year is 446 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [What is primary energy use?](#)

## Additional information

Additional information about this property:

- Dwelling may have narrow cavities

### Environmental impact of this property

This property's current environmental impact rating is F. It has the potential to be B.

Properties are rated in a scale from A to G based on how much carbon dioxide (CO<sub>2</sub>) they produce.

Properties with an A rating produce less CO<sub>2</sub> than G rated properties.

### An average household produces

6 tonnes of CO<sub>2</sub>

### This property produces

6.2 tonnes of CO<sub>2</sub>

### This property's potential production

1.7 tonnes of CO<sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 4.5 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

**How to improve this property's energy performance**

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from E (42) to B (84).

► [What is an energy rating?](#)

Potential energy  
rating

**B**

**Recommendation 1: Flat roof or sloping ceiling insulation**

Flat roof or sloping ceiling insulation

**Typical installation cost**

£850 - £1,500

**Typical yearly saving**

£74

**Potential rating after carrying out recommendation 1**

45 | E

**Recommendation 2: Cavity wall insulation**

Cavity wall insulation

**Typical installation cost**

£500 - £1,500

**Typical yearly saving**

£50

**Potential rating after carrying out recommendations 1 and 2**

47 | E

**Recommendation 3: Internal or external wall insulation**

Internal or external wall insulation

**Typical installation cost**

£4,000 - £14,000

**Typical yearly saving**

£124

**Potential rating after carrying out recommendations 1 to 3**

52 | E

**Recommendation 4: Low energy lighting**

Low energy lighting

**Typical installation cost**

£35

**Typical yearly saving**

£38

**Potential rating after carrying out recommendations 1 to 4**

54 | E

**Recommendation 5: Change room heaters to condensing boiler**

Condensing boiler

**Typical installation cost**

£3,000 - £7,000

**Typical yearly saving**

£456

**Potential rating after carrying out recommendations 1 to 5**

71 | C

**Recommendation 6: Flue gas heat recovery device in conjunction with boiler**

Flue gas heat recovery

**Typical installation cost**

£400 - £900

**Typical yearly saving**

£26

**Potential rating after carrying out recommendations 1 to 6**

72 | C

**Recommendation 7: Solar water heating**

Solar water heating

**Typical installation cost**

£4,000 - £6,000

**Typical yearly saving**

£27

**Potential rating after carrying out recommendations 1 to 7**

73 | C

**Recommendation 8: Solar photovoltaic panels, 2.5 kWp**

Solar photovoltaic panels

**Typical installation cost**

£5,000 - £8,000

**Typical yearly saving**

£278

**Potential rating after carrying out recommendations 1 to 8**

84 | B

**Paying for energy improvements**

Find energy grants and ways to save energy in your home. (<https://www.gov.uk/improve-energy-efficiency>)

**Estimated energy use and potential savings**

## Estimated yearly energy cost for this property

£1437

---

## Potential saving

£795

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

#### Space heating

12187 kWh per year

---

#### Water heating

1531 kWh per year

---

## Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
Loft insulation	3522 kWh per year
Cavity wall insulation	580 kWh per year
Solid wall insulation	1468 kWh per year

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

### Assessor's name



Garry Bullock

---

**Telephone**

08450945192

---

**Email**

[enquiries@vibrantenergymatters.co.uk](mailto:enquiries@vibrantenergymatters.co.uk)

---

**Accreditation scheme contact details**

**Accreditation scheme**

ECMK

---

**Assessor ID**

ECMK300186

---

**Telephone**

0333 123 1418

---

**Email**

[info@ecmk.co.uk](mailto:info@ecmk.co.uk)

---

**Assessment details**

**Assessor's declaration**

No related party

---

**Date of assessment**

15 September 2016

---

**Date of certificate**

16 September 2016

---

**Type of assessment**

▶ [RdSAP](#)

---

**Other certificates for this property**

02/12/2021, 14:21

Energy performance certificate (EPC) - Find an energy certificate - GOV.UK

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.